

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30-8-2025

It is certified that an inspection team headed by Sri V. Raja Rao Senior Water Analyst.
(Name of Officers with designation) from Regional public Health Laboratory, Guntur.
inspected the Ravindra Bhavathi's Scotspine School, Kanuru, Tadigadapa.

(Name & Address of the school) on 26-08-2025 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 5880, 5881 dated 30-8-2025

of Regional public Health Laboratory (PHED Lab) certified that
the Ravindra Bhavathi's Scotspine School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till One year.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To Ravindra Bhavathi's scotspine school.

Rs. NO. 168/2, 168/2J, 168/3

(Name & Address of the Institution)

Kanuru, Tadigadapa Municipality
Krishna Dist.

R. Prasad 30/8/25.

V. RAJA RAO

senior Water Analyst.

Regional

Public Health Laboratory

Senior Analyst (Water)

Regional Laboratory

Medical College Campus

Guntur-4.

Note: The certificate is to be issued by authorized officer, PHED, Lab / local bodies



GOVERNMENT OF ANDHRAPRADESH
DIRECTORATE OF I.P.M.PH. LABS, FOOD (H) ADMN, MANGALAGIRI, GUNTUR DISTRICT
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	Ravindra Bharathi's Scotspine School, RS No: 168/2,168/2J,168/3, Kanuru,Tadigadapa Municipality, Krishna Dt.	Lab. Ref. No:	5880
		Collected on	26.08.2025
		Received on	26.08.2025
Collected by	Staff	Source Profile	Ro Water

		Source / Sample	Limits as per IS 10500:2012	
		Drinking water tap (Ro) at above address.		
S.No	Parameter		Desirable (Acceptable limit)	Permissible limit in the absence of alternative source
Physical Parameters				
1	Colour (Hazen units)	<5.0	5	15
2	Turbidity in NTUS`	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeable
4	pH	7.1	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	110	...	
6	TDS (mg/L)	72	500	2,000
Chemical parameters (mg/L)				
1	Alkalinity (as CaCO ₃)	Nil	...	
2	Total Alkalinity. Max	20	200	600
3	Total hardness max	24	300	600
4	Calcium hardness (as CaCO ₃)	12	..	
5	Magnesium hardness (as CaCO ₃)	12	..	
6	Calcium (as Ca)	5.0	75	200
7	Magnesium (as Mg)	3.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	24	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample is not fit for drinking purpose.

Remarks: The given sample physico chemically all the analysed parameters are within the desirable limits and satisfactory for drinking purpose.



R. p. n. u. 30/8
Senior Analyst* (Water)
Regional Laboratory
Medical College Campus
Guntur-4.

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Gollapudi, Vijayawada
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from: Ravindra Bharathi's Scotspine School, RS No: 168/2,168/2J,168/3,
Kanuru, Tadigadapa Municipality, Krishna Dt.

Collected on: 26.08.2025

Received on: 26.08.2025

Paid / Free: Paid

Collected by : self.

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MP N of Esch coli.
1	5881	Drinking water tap(Ro) at above address.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically satisfactory for drinking purpose as evidenced by the Nil MPN count of coliform bacteria.



R p new
30/8
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4.